

CERTIFICATE



TÜV NORD CERT GmbH
herewith declares that

Aplicaciones Técnicas de la Energía S.L.
Avda de la Foia 14, 46440, Almussafes, Valencia
Spain

is authorized to provide the product mentioned below with the mark as illustrated:



Description of product (details see Annex 2):

PV Modules with 6" Poly-crystalline Silicon Solar Cells

Valid until: 2018-06-16

Tested according to: IEC / EN 61215:2005;
IEC 61730-1:2004+A1:2011+A2:2013 / EN 61730-1:2007+A1:2012+A2:2013;
IEC 61730-2:2004+A1:2011 / EN 61730-2:2007+A1:2012.

Registered No.: 44 780 16 406749 - 074

Manufacturer: see Annex 1

Test Report No.: 492010643.001

File No.: SHV01030/16

TÜV NORD CERT GmbH
Certification Body
Consumer Products

Essen, 2016-04-12

Please also pay attention to the information stated overleaf.

Anlage 1 zum Zertifikat Nr.: / Annex 1 to Certificate No.: 44 780 16 406749 - 074

Seite / Page 1 von / of 1

Aktenzeichen: / File reference: SHV01030/16

2016-04-12

Manufacturer:

Manufacturer: **Coded by debtor no. 55246207**

Factory inspection report no.: 862010190.003

Remark:

Factory inspection is mandatory to be performed annually. Please refer to factory inspection report for detailed information.

A handwritten signature in blue ink, appearing to read "Rogers K1".

TÜV NORD CERT GmbH
Certification Body
Consumer Products

Description of product(s):

Module types:	PV Modules with 6" Poly-crystalline Silicon Solar Cells 72 cells: A-***P GS (***) = 275-350, in increment of 5) 72 cells: A-***P GS MN TN (***) = 275-350, in increment of 5) 60 cells: A-***P GS (***) = 235-270, in increment of 5) 60 cells: A-***P GS MN TN (***) = 235-270, in increment of 5)
Maximum system voltage:	1000V
Fuse rating:	15A
Application class:	Class A
Electrical protection class:	Class II
Fire safety class:	Class C
Rated mechanical load:	2400Pa

Remark:

For detailed product information, please refer to CDF (Constructional Data Form) in Annex 1 of test report.



TÜV NORD CERT GmbH
Certification Body
Consumer Products